

## SOUTHERN CALIFORNIA GAS COMPANY PIPELINE/STATION MAINTENANCE SCHEDULE

Location Type	Location	Start Date	End Date	Maintenance Type	Description	Capacity Reduction (MMCF)	Capacity Reduction (Dth)
Area Zone	Needles/Topock Area Zone	09/17/2018	TBD	Planned	Restricted operation of L4000 and L235 outage.	1070	1098890
Storage Field - Inj	Aliso Canyon	07/03/2018	TBD	Unplanned	Reduced well availability due to Storage Integrity Management Program (SIMP).	145	148045
Storage Field - Inj	Goleta	02/23/2017	TBD	Unplanned	Mechanical limitations at Olive Street Compressor Station	20	20420
Storage Field - Inj	Goleta	03/12/2013	TBD		Non Maintenance related due to North Coastal demand and available supply.	45	45945
Storage Field - Inj	Honor Rancho	06/08/2018	TBD	Planned	Well Limitation/ Field Inventory	40	40840
Storage Field - Inj	Honor Rancho	02/13/2016	TBD	Unplanned	Unplanned - Main unit horsepower and RPM reductions required due to mechanical limitations.	50	51050
Storage Field - Inj	Playa del Rey	08/20/2018	09/20/2018 11:59:59 PM PCT	Planned	Install relief valves on each unit	25	25525
Storage Field - Inj	Playa del Rey	08/15/2018	08/15/2018 11:59:59 PM PCT		Fuel System Repair	50	51050
Storage Field - Inj	Playa del Rey	08/10/2018	08/14/2018 11:59:59 PM PCT		Fuel System Repairs	50	51050
Storage Field - Inj	Playa del Rey	08/05/2018	TBD	Unplanned	CB8 High Cylinder Temp Shutdown	25	25525
Storage Field - Wth	Aliso Canyon	12/19/2015	TBD		Withdrawal from Aliso canyon is discontinued unless needed for system reliability.	1850	1888850
Storage Field - Wth	Goleta	02/22/2018	TBD	Unplanned	Due to Field Inventory	20	20420
Storage Field - Wth	Goleta	12/01/2017	TBD	Planned	Storage Integrity Management Program (SIMP)	135	137835
Storage Field - Wth	Honor Rancho	12/01/2017	TBD	Planned	Well Limitation/ Field Inventory	165	168465
Storage Field - Wth	Honor Rancho	03/15/2017	TBD	Planned	Storage Integrity Management Program (SIMP)	180	183780
Storage Field - Wth	Playa del Rey	08/15/2018	08/17/2018 11:59:59 PM PCT	Planned	Group 3 withdrawal wells OOS to install new lateral	80	81680
Storage Field - Wth	Playa del Rey	08/14/2017	TBD		Due to Well Availability	90	91890
Sub-Zone	EP-Ehrenberg/NBP-Blythe	03/29/2018	TBD	Planned	L2000 Right of Way Expiration.	30	31110
Sub-Zone	EP-Ehrenberg/NBP-Blythe	01/02/2015	TBD		L2000 - Planned Outage - Voluntary decrease of maximum operating pressure on L2000 Southern Transmission Zone by approximately 20%. This change is being made to further improve and maintain the safety of So Cal Gas pipelines. Note: Original Job start date 8-5-2011.	202	209474
Sub-Zone	PGE-Wheeler Ridge/EH GOS-Wheeler Ridge	08/14/2018	08/17/2018 11:59:59 PM PCT	Planned	L7200 In Line Inspection (ILI)	120	123480

Location Type	Location	Start Date	End Date	Maintenance Type	Description	Capacity Reduction (MMCF)	Capacity Reduction (Dth)
Sub-Zone	TW-Needles/QST-Needles	12/23/2017	TBD	Force Majeure	L235-2	530	543250
Sub-Zone	TW-Topock/EP-Topock	07/29/2016	09/16/2018 11:59:59 PM PCT	Unplanned	L3000 Necessary Remediation.	540	555120
Zone	CP-Line 85	01/31/2018	TBD	Unplanned	Line 85 zone is reduced as a result of pipeline safety enhancements	75	80925
Zone	Southern Zone	03/10/2018	TBD	Critical	Zone reduction due to system conditions.	510	531930

Although SoCalGas has used reasonable efforts to assure its accuracy and timeliness, this information is preliminary operational data and can be negatively impacted by delays or errors in electronic transfers, data entry, communication failures, or other causes. No representation is made that the contents are free from error. SoCalGas assumes no responsibility for use of, or reliance on, this information by any party, and specifically advises such parties to discuss any decisions or actions related hereto with their own advisors and experts. Please also note that Storage field injection/withdrawal capacities are adjusted periodically depending on field pressures.

**Last updated: 08/15/2018 08:00:39 AM PCT**

Legend
<b>New</b>
<b>Revised Entry</b>
<b>Deleted</b>
<b>Completed/Expired</b>